



TEST REPORT.

وزارة البيئة والمياه والزراعة
Ministry of Environment, Water & Agriculture
المملكة العربية السعودية
Kingdom of Saudi Arabia



Report ID	Report Date	Page
R-29244850-22	24/10/2022	1 of 1

Customer Name \ Address	indian school				
Sample Collected By	By Sampler	Collection Date/Time	-	Received Date/Time	19.10.2022 12:30

Sample #	Description	Test Date
797599	Companies samples received	19.10.2022
-	-	-
-	-	-
-	-	-

Test	Test Method	LOQ	Unit	MU (±) @95%CL	Spec (GSO 149:14)	Sample # / Test Result			
						797599			
Colour	APHA-2120-C	N/A	-		Max 15	2			
Taste odour	APHA-2150-B	N/A	-		Not Found	Not Found			
pH*	APHA-4500-H+B	N/A	-	5.37	6.5 to 8.5	8.12			
Turbidity*	APHA-2130-B	N/A	NTU	19	Max 5	0.33			
Nitrite	APHA-4500-NO2-B	N/A	mg/L		Max 3	0			
Ammonia	APHA 4500 NH3 F	N/A	mg/L		Max 0.5	0			
Calcium Ion		N/A	mg/L		-	19			
Chlorine	4500-Cl G	N/A	mg/L		0.2 to 0.5	*0*			
Conductivity*	APHA-2510-B	N/A	µS/cm	16	-	216			
E Coli	APHA-9230-C	N/A	MPN/ 100ml		-	1			
Iron	APHA-3500-Fe-B	N/A	mg/L		Max 0.3	0			
Total Coliforms	APHA_9222	N/A	mg/L		-	1			
Total Dissolved Solids	By Calculation	N/A	mg/L	15	100 to 1000	108			

	Chemistry	Micro Biology	Approval
Name			Shakr G. Alghanam
Function	Supervisor	Supervisor	Lab Manager
Date	24-Oct-2022	24-Oct-2022	24-Oct-2022
Signature			

CHAIRMAN

PRINCIPAL